

# ATTESTATION OF CONFORMITY



**BUREAU  
VERITAS**

Attestation No.: 1788AS0207N030001

**Equipment:** Hybrid Photovoltaic Inverter

**Brand Name:** --

**Test Model No.:** InfiniSolar Super 4KW

**Applicant:** VOLTRONIC POWER TECHNOLOGY CORP.  
5F, No. 151, Xinhua 1st Road, Neihu District,  
Taipei, Taiwan

**Test Report No.:** PV170207N030



## Use in accordance with regulations:

Automatic disconnection device with single-phase mains surveillance in accordance with EN 50438:2013 for photovoltaic systems with a single-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter.

At the time of issue of this certificate the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

**EN 50438:2013,  
DIN V VDE V 0126-1-1:2006-02 (Functional safety)**

---

---

Ted Wu/ Senior Manager/ PV Inverter Team  
April 06, 2017

No. 34, Chenwulu Section, Guantai Rd., Houjie Town,  
Dongguan City, Guangdong 523942, China.  
Tel: +86 769 8593 5656; Fax: +86 769 8593 1080.  
Email: customerservice.dg@cn.bureauveritas.com  
<http://ee.bureauveritas.com.tw/cn/>

